



KWIK-WALL

MOVEABLE WALL SYSTEMS

Model 3020WT Individual Panels / Multi-Directional (Weight Transfer)

Introduction:

The following three (3) part specification offers the Standard and *Optional* features for the Model 3020WT (Weight Transfer) Multi-Directional Operable Wall System. The yellow highlighted areas in the specification indicate an *Optional* selection that is available based on your project requirements.

In order to assist you with the design criteria KWIK-WALL has provided a Product Guide and Track & Carrier Selection Chart for the Model 3020WT.

The Product Guides indicate the acoustical ratings (STC) available, and also establishes the maximum partition height and width.

MODEL 3020WT PRODUCT GUIDE STANDARD STEEL SKIN CONSTRUCTION				
STC RATING	(NOMINAL) PANEL THICKNESS	MAX. PANEL WEIGHT (lbs. / ft ²)	MAXIMUM PANEL HEIGHT	MAXIMUM WALL WIDTH
46	3 1/2" [89]	8.5 (41 kg/m ²)	12'-2" (3.71 m)	UNLIMITED
50	3 1/2" [89]	9.5 (46 kg/m ²)	12'-2" (3.71 m)	UNLIMITED
52	3 1/2" [89]	9.5 (46 kg/m ²)	12'-2" (3.71 m)	UNLIMITED
55	3 1/2" [89]	12.9 (63 kg/m ²)	12'-2" (3.71 m)	UNLIMITED

MODEL 3020WT PRODUCT GUIDE OPTIONAL ACOUSTICAL SUBSTRATE SKIN CONSTRUCTION				
STC RATING	(NOMINAL) PANEL THICKNESS	MAX. PANEL WEIGHT (lbs. / ft ²)	MAXIMUM PANEL HEIGHT	MAXIMUM WALL WIDTH
43	3 1/2" [89]	5.9 (29 kg/m ²)	12'-2" (3.71 m)	UNLIMITED
46	3 1/2" [89]	6.6 (32 kg/m ²)	12'-2" (3.71 m)	UNLIMITED
48	3 1/2" [89]	7.5 (37 kg/m ²)	12'-2" (3.71 m)	UNLIMITED
50	3 1/2" [89]	9.0 (44 kg/m ²)	12'-2" (3.71 m)	UNLIMITED

The Track & Carrier Selection Chart determines the appropriate track and carrier system based on the STC Rating and Panel Fabrication Height.

MODEL 3020WT - TRACK AND CARRIER SELECTION CHART			
Panel Skin Type	Maximum Panel Weight lbs./ft. ²	STC Rating	Panel Fabrication Height
			Up to 12'-2" (3.71 m)
Acoustical Substrate	5.9 (29 kg/m ²)	43	
Acoustical Substrate	6.6 (32 kg/m ²)	46	
Acoustical Substrate	7.5 (37 kg/m ²)	48	
Acoustical Substrate	9.0 (44 kg/m ²)	50	850 Track and Carriers
Steel Skins	8.5 (42 kg/m ²)	46	
Steel Skins	9.5 (46 kg/m ²)	50	
Steel Skins	9.5 (46 kg/m ²)	52	
Steel Skins	12.9 (63 kg/m ²)	55	

Model 3020WT Individual Panels / Multi-Directional (Weight Transfer) Product Specification

PART 1 – GENERAL SPECIFICATIONS

1.01 WORK INCLUDED

- A. Operable Wall System shall be furnished, installed and serviced by wall manufacturer's authorized distributor, in compliance with the architectural drawings and specifications contained herein.

1.02 RELATED WORK

- A. Structural Support: Structural support system required for suspending the operable wall shall be designed, installed and pre-punched by others, in accordance with ASTM E557 and manufacturer's shop drawings.
- B. Insulation: Sound insulation and baffles for the plenum area above the track system, under the permanent floor, inside air ducts passing over or around the operable wall, and in permanent walls adjoining the operable wall system shall be by others, in accordance with ASTM E557.
- C. Opening Preparation: Proper and complete preparation of the operable wall system opening shall be by others in accordance with ASTM E557, and shall include floor leveling; plumbness of adjoining permanent walls; substrate and/or ceiling tile enclosures for the track system; and the painting and finishing of trim and other materials adjoining the head and jamb areas of the operable wall. Any permanent wall(s) receiving an adjustable or fixed wall jamb will require internal structural blocking in order to secure the jamb to the permanent wall. Refer to a copy of the shop drawings for additional details.

1.03 SYSTEM DESCRIPTION

- A. The operable wall system shall consist of Individual Panels that are top supported by two (2) multi-directional carriers that are capable of negotiating 90° "X", "L" and "T" intersections.
- B. The operable wall system shall consist of acoustically rated panels tested in accordance with ASTM E90 and ASTM E413 test procedures, and shall have achieved a STC rating as specified herein (see "Acoustical Performance" article listed under Part 2 – Products).

1.04 QUALITY ASSURANCE

- A. The operable wall shall have been tested in an independent acoustical testing laboratory in accordance with ASTM E90 and ASTM E413 test procedures.
- B. The operable wall panel construction and finish materials shall consist of Class A rated materials in accordance with ASTM E84.
- C. The operable wall shall be installed by the manufacturer's authorized distributor in accordance with ASTM E557.

1.05 REFERENCES

- A. ASTM E90: Laboratory Measurement of Airborne-Sound Transmission Loss of Building Partitions.
- B. ASTM E413: Determination of Sound Transmission Class (STC).
- C. ASTM E557: Architectural Application and Installation of Operable Partitions.
- D. ASTM E84: Surface Burning Characteristics of Building Materials.
- E. ASTM A653: Specification for General Requirements for Steel Sheet, Alloy-Coated (Galvannealed) by the Hot Dip Process.
- F. ASTM C423: Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method.
- G. CCC-W-408A-D: Federal Specification which applies to Vinyl Coated Wall Coverings.

- H. CFFA-W-101-B: Chemical Fabrics and Film Association Quality Standard for Vinyl Coated Fabric Wall Coverings.

1.06 SUBMITTALS

- A. Manufacturer shall provide written technical information and related detail drawings, which demonstrate that the products comply with contract documents for each type of operable partition specified.
- B. Manufacturer shall provide detailed engineering drawings featuring track plan, panel elevation, horizontal and vertical details and beam punching template as required.
- C. Manufacturer shall provide written test report of the independent acoustical testing laboratory certifying the attainment of the specified STC rating, upon request.
- D. Manufacturer shall provide written instructions specifying the proper operation and maintenance of the operable wall system.
- E. Manufacturer shall provide a color selector demonstrating the manufacturer's selections of the specified finish material. Samples shall consist of actual swatches of the specified finish material.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Panels shall be individually wrapped in a protective plastic covering to keep panels clean during delivery, storage and handling.
- B. Panels shall be stored on edge and above the floor on cushioned blocking in a dry and ventilated area, protected from humidity and temperature extremes.

1.08 SEQUENCING / SCHEDULING

- A. Beam Punching: Manufacturer shall provide beam punching template drawing detailing the anchor locations for the suspended track system (as required for Drop Rod Mounting), as required for the fabrication and installation of structural overhead support by others.
- B. Track Installation: Scheduling of operable wall track installation shall occur after structural overhead support has been properly and completely fabricated and installed by others.
- C. Panel Installation: Operable wall panel installation shall occur after fixed wall substrate construction is properly and completely installed by others, as required to protect panels from ongoing adjacent construction.

1.09 WARRANTY

- A. Manufacturer shall warrant each partition and its component parts to be free from defects in material and workmanship for a period of two (2) years from the date of delivery to the original purchaser, when installed by an authorized KWIK-WALL distributor.

PART 2 – PRODUCT SPECIFICATIONS

2.01 ACCEPTABLE MANUFACTURER

- A. Operable walls shall be Series 3000, Model 3020WT Individual Panels / Multi-Directional *Weight Transfer* as manufactured by KWIK-WALL Company.

2.02 PANEL CONSTRUCTION

- A. Panel Dimensions: Standard panel dimension shall be a nominal 3 1/2" [89] thick.
- B. Panel Frame: Steel frame shall be 16-gauge galvanized steel, which meets or exceeds ASTM A653 requirements. Frame shall be all-welded construction with steel corner supports and cross-bracing reinforcement. Panel frame shall be Class A rated, fire retardant, non-combustible and non-corrosive in accordance with ASTM E84.
- C. Panel Skins: Panel skins shall be Class A rated in accordance with ASTM E84. Panel skin material shall consist of (select):

1. *Standard Steel Skins*: consisting of minimum 22-gauge tension-leveled galvalume steel, pressure laminated to a structural acoustical backer and welded to the steel frame to form a rigid, unitized and structural panel.
2. *Optional Acoustical Substrate*: consisting of structural acoustical substrate pressure laminated to both sides of the steel frame to form a rigid, unitized and structural panel.

D. Panel Weight: Maximum panel weight shall be 5.9 – 12.9 lbs./ft.² (29 – 63 kg/m²) depending on STC rating, size and options selected.

2.03 OPERATION

A. Operation shall be Individual Panels with a Multi-Directional track system that allows the panels to negotiate 90° “X”, “L” and “T” intersections as required for movement of panels from storage location(s) to various installed positions. Panels shall be top supported by two (2) carriers featuring dual horizontal precision bearings with high strength polymer tires riding on a structural aluminum track.

2.04 STACK ARRANGEMENTS

A. Stack Type: Panel storage configuration shall be (select):

1. *Standard Perpendicular Stack*: consisting of panels stacked perpendicular to the wall's installed position.
2. *Optional Parallel Stack*: consisting of panels stacked parallel to the wall's installed position.
3. *Optional Remote Stack*: consisting of panels located remotely from the wall's installed position, as shown on submitted shop drawings.

B. Stack Quantity: Panels shall be stored in separate stack areas as required for panel storage.

2.05 FINISHES

A. Finish Material Type: Panel finish material shall be Class A rated in accordance with ASTM E84, consisting of (select):

1. *Standard Vinyl*: consisting of Type I, reinforced vinyl weighing 15 oz./lin. yd. (465 g/lin. m). Standard Vinyl shall meet or exceed CCC-W-408A-D and CFFA-W-101-B quality standards.
2. *Optional Basic Carpet*: consisting of acoustically absorbent, non-woven needle punch fibers fused to prevent fraying and unraveling of material weighing 22.5 oz./lin. yd. (698 g/lin. m). Basic Carpet shall achieve a minimum NRC rating of .65 in accordance with ASTM C423.
3. *Optional Upgrade Vinyl*: consisting of Type II, reinforced vinyl weighing 20 oz./lin. yd. (620 g/lin. m). Upgrade Vinyl shall meet or exceed CCC-W-408A-D and CFFA-W-101-B quality standards.
4. *Optional Upgrade Carpet*: consisting of acoustically absorbent, non-woven needle punch fibers fused to prevent fraying and unraveling of material weighing 23 oz./lin. yd. (713 g/lin. m). Upgrade Carpet shall achieve a minimum NRC rating of .60 in accordance with ASTM C423.
5. *Optional Upgrade Fabric*: consisting of fade and tear resistant fabric that resists water-based stains weighing 16 oz./lin. yd. (496 g/lin. m).
6. *Optional Unfinished*: consisting of panels with exposed acoustical substrate or steel skins for field applied wallcovering or painting.

B. Finish Material Supplier: Finish material shall be (select):

1. *Standard Factory Supplied*: from manufacturer's standard selection of finish materials, as specified.
2. *Optional Customer Supplied*: from customer's selection of finish material, by others, and as approved by KWIK-WALL Company.

C. Finish Material Application: Finish material shall be (select):

1. *Standard Factory Applied*: by operable wall manufacturer. Customer supplied finish material samples must be submitted to manufacturer for testing and approval prior to acceptance and application.
2. *Optional Field Applied*: by others.

2.06 PERIMETER TRIM AND SEALS

- A. Vertical Trim and Seals: Panels shall have vertical astragals containing flexible vinyl seals and incorporate reversible tongue-and-groove-type configurations for positive interlocking with adjacent panels. Vertical astragal type shall be (select):
1. *Standard Trimless Astragal*: consisting of an aluminum extrusion with tongue-and-groove-type vertical astragals. Vertical trim shall not be permitted on the panel faces, resulting in a minimal groove appearance between adjacent panels.
 2. *Optional Cap-type Astragal*: consisting of an aluminum extrusion with tongue-and groove-type vertical astragals for protecting the finish material and substrate along the vertical edge of the panel.
- B. Horizontal Top Trim and Seals: Top seals shall consist of flexible vinyl sweep seals installed on both sides of the panel. The seals shall consist of a compressed bulb between two (2) fingers of vinyl. Top seal type shall be fixed providing continuous-contact flexible vinyl, which seals against the bottom flange of the overhead track.
- C. Horizontal Bottom Trim and Seals: Bottom seals shall consist of multiple fingers of flexible vinyl for positive contact and sealing with various floor surfaces. *Standard Weight Transfer Operable Bottom Seal* shall consist of an edge-activated seal capable of transferring the weight of a panel (850 lbs. maximum (386 kg)) from the overhead structural support to the floor using a removable wrench as supplied by manufacturer. Bottom seals shall provide 2 3/4" [70] of nominal travel.

2.07 CLOSURE SYSTEMS

- A. Initial Closure System: The lead panel (the first panel exiting the stack) shall form a seal vertically against a rigid wall surface, as accomplished by a (select):
1. *Standard Bulb Seal*: consisting of continuous-contact, flexible vinyl bulb seals installed along the vertical edge of the lead panel for positive compression against a rigid wall surface.
 2. *Optional Fixed Starter Jamb*: consisting of an aluminum extrusion, which is permanently mounted to a structural wall surface. The Fixed Starter Jamb shall incorporate a tongue-and-groove-type vertical astragal for positive interlocking with the lead panel.
 3. *Optional Adjustable Starter Jamb*: consisting of an aluminum extrusion which is permanently mounted to a structural wall surface and is field-adjustable to compensate for out-of-plumb conditions of the fixed wall. The Adjustable Starter Jamb shall incorporate a tongue-and-groove-type vertical astragal for positive interlocking with the lead panel.
- B. Final Closure System: The final closure panel (the last panel exiting the stack) shall form a seal vertically against a rigid wall surface. The type of final closure panel shall be (select):
1. *Standard Expander Panel Closure*: consisting of an expander mechanism with a nominal 5" [127] of travel, activated from the face of the panel using a removable wrench as supplied by manufacturer. The Expander Panel shall be equipped with an adjustable bottom seal (standard) or (optional) floating or operable bottom seals, and a flush pull handle on one side of the panel.
 2. *Optional Hinged Panel(s) Closure*: consisting of a panel hinged permanently and directly to a structural wall surface. The Hinged Panel(s) shall be equipped with an adjustable bottom seal, a lap-type extrusion for sealing against its adjacent panel, and a flush pull handle on each side of the panel.
 3. *Optional Pocket Door(s)*: (see "Series 3000 Pocket Door" brochure for complete details and specifications).

2.08 ACOUSTICAL PERFORMANCE

- A. Certification: The operable wall shall have been tested in an independent acoustical testing laboratory in accordance with ASTM E90 and ASTM E413 test procedures.
- B. STC Rating: The operable wall acoustical performance rating shall be based on (select):
1. *Standard Steel Skins*: with a standard rating of 52 STC, or optional ratings of 46 STC, 50 STC or 55 STC.
 2. *Optional Acoustical Substrate*: with optional ratings of 43 STC, 46 STC, 48 STC or 50 STC.

2.09 PANEL ACCESSORIES

- A. Standard accessories including pass doors, exit signs, writing surfaces, chalktrays, vision lites, tack surfaces and pocket doors shall be compatible with other accessories and options, furnished and installed by the operable wall manufacturer as noted on submitted shop drawings.

2.10 TRACK SYSTEM

- A. Type 850 Multi-Directional Aluminum Track: The operable wall track system shall be certified for up to 850 lbs. (386 kg) of total live load weight per panel, and extruded from structural aluminum alloy, which prohibits deterioration caused by rust or corrosion. The aluminum track shall have a durable anodized clear satin finish, which resists scratching, color fading and flaking. The track shall utilize grooves and interlocking steel pins for positive alignment of adjacent track sections. The track joints shall be reinforced overhead by a heavy-duty steel bracket made of hot-rolled, 3/8" [10] thick plate steel. Aluminum track shall include an integral nut slot to accept a hardened steel square nut to facilitate attachment of each steel all-rod and splice brackets to the overhead structural support.

2.11 CARRIER SYSTEM

- A. Type 850 Multi-Directional Carrier: Each Individual Panel shall be top supported by two (2) carriers capable of supporting up to 850 lbs. (386 kg) of total live load weight per panel, utilizing a 5/8" [16] diameter pendant bolt. Each carrier shall consist of dual horizontal, permanently lubricated, precision ground steel bearings with high strength polymer tires as required for smooth and quiet operation. Multi-Directional carriers shall be capable of negotiating 90° "X", "L" and "T" intersections as required for moving panels from storage location(s) to various installed positions.

2.12 SUSPENSION SYSTEM

- A. Mounting System: The track shall be supported by steel Drop Rods, consisting of adjustable rods of grade 2, 3/8" [10] diameter threaded steel all-rod provided with 3/8" [10] serrated steel nuts.

PART 3 – EXECUTION

3.01 INSPECTION

- A. Proper and complete preparation of the operable wall system opening shall be by others in accordance with the architectural drawings, manufacturers shop drawings and ASTM E557. Any deviation of the actual opening from these specifications shall be called to the attention of the architect prior to the installation of the operable wall.
- B. Deficiencies in the operable wall opening shall be corrected by others prior to installation of the operable wall.

3.02 INSTALLATION

- A. The operable wall system shall be installed by manufacturer's authorized distributor.
- B. The operable wall shall be installed in accordance with manufacturer's written instructions, shop drawings and ASTM E557 installation guidelines.

3.03 ADJUSTING AND CLEANING

- A. The operable wall panels and track system shall be adjusted and cleaned in accordance with manufacturer's written instructions.

3.04 PROTECTION

- A. The operable wall panels shall be stored in the stacked (retracted) position prior to acceptance by the owner's representative.

3.05 DEMONSTRATION

- A. The operable wall manufacturer's authorized distributor shall demonstrate proper operation and explain proper and necessary maintenance requirements of the operable wall system to the owner's representative.

For additional information contact:

KWIK-WALL Company
1010 East Edwards Street
Springfield, Illinois 62703

Phone: 217-522-5553

Fax: 217-522-1170 or 800-290-5945

Website: www.kwik-wall.com

Email: kwinfo@kwik-wall.com

Note:

Due to ongoing research and development, some variations may occur in product specifications.

06/03